Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RK850

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WOLF, CLYDE	Phone #: (715)257-1953
Mailing Address: 15595 CO RD S	
City: ATHENS	State: WI — Zip Code: 54411
County: Clark	Co. Permit #:
Notification #	Completed: 05-22-2003
Well Constructor (Business Name): KLINE WELL & PUMP INC	Lic. #: 6010
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: PO BOX 176 LOYAL WI 54446	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.2	

1. Well Location

Town of LONGWOOD

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE	SE	Section	Township	Range
or Govt Lot #		35	28 N	2 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of SHOP

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	38.5
6	38.5	84

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	9
-	-	N	-	SANDSTONE	9	47
-	-	Q	-	GRANITE	47	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# NEW STEEL ASTMA53B WELDED SAWHILL	Surface	38.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 38 ft. below surface

Pumping at 4.5 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	38.5	7 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		06-17-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		30

Comment:

Created On: 07-11-2003 Updated On: 09-03-2003 Review Status: