Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RL187

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LEIKNESS-STAHL FUNERAL HOME	Phone #: (715)335-4300
Mailing Address: PO BOX 296	
City: PLAINFIELD	State: WI — Zip Code: 54966
County: Waushara	Co. Permit #: — Notification #: — Completed: 08-22-2003
Well Constructor (Business Name): JOE FARAGO	Lic. #: 284 — Facility ID # (Public Wells):
Address: FARAGO PLBG & TRENCHING INC, PLAINFIELD WI 54966	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3

1. Well Location

Village of PLAINFIELD	Fire # (if avail.): 913
Street Address or Road Name and Number: W NORTH ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.2134 °N -89.5041 °W	Method Code: GCD013
NE NE or Govt Lot #:	Section: 14 — Township: 20 N — Range: 8 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves # of POND
Private, non-potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	48.1

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	48.1

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTMA589 .237 WALL SAWHILL 11#/FT T&C	Surface	44
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	SLOT 15 STAINLESS	44	48

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-08-2003 Updated On: 05-05-2020 Review Status: