

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RL187		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LEIKNESS-STAHN FUNERAL HOME						Phone # (715)335-4300		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 296						Village of PLAINFIELD						913					
City PLAINFIELD						State WI		Zip Code 54966				Street Address or Road Name and Number					
County Waushara						Co. Permit #		Notification #		Completed 08-22-2003		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) JOE FARAGO						Lic. # 284		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.2134 °N -89.5041 °W				Method Code GCD013			
Address FARAGO PLBG & TRENCHING INC PLAINFIELD WI 54966						Well Plan Approval #		NE NE		Section 14		Township 20 N		Range 8 E			
								or Govt Lot #									
Approval Date (mm-dd-yyyy)						2. Well Type New Well											
Hicap Permanent Well #						Common Well #		Specific Capacity 3		of previous unique well #				constructed in			
3. Well serves # of POND						Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, non-potable						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
4		Surface		48.1													
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Yes				No							
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)							
-		-		Y		-		SAND & GRAVEL		Surface		48.1					
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level							
4		ASTMA589 .237 WALL SAWHILL 11#/FT T&C				Surface		44		16 ft. below ground surface							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is							
4		SLOT 15 STAINLESS				44		48		14 in. above grade							
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test							
				Surface						Developed ? Yes							
Filled & Sealed Well(s) as needed?																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller																	
JF				Lic #		Date Signed											
Drill Rig Operator				Lic or Reg #		Date Signed											

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-08-2003

Updated On: 05-05-2020

Review Status: