Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RM324

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BANGART, KIM	Phone #: (920)853-3080
Mailing Address: W2070 SCHNEIDER RD	
City: HILBERT	State: WI Zip Code: 54129
County: Calumet	Co. Permit #:	Notification #:	Completed: 09-05-2003
Well Constructor (Business Name): ROGER WEBER	Lic. #: 99	Facility ID # (Public Wells):
Address: WEBER WELL DRILLING, CHILTON WI 53014	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3

1. Well Location

Town of RANTOUL			Fire # (if avail.): W2070
Street Address or Road Name and Number: W2070 SCHNEIDER RD			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.1117 °N -88.1415 °W			Method Code: GCD013
SW SW or Govt Lot #:	Section: 17	Township: 19 N	Range: 20 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	98

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	RED CLAY	Surface	58
-	-	Y	-	SAND & GRAVEL	58	75
-	B	L	-	BROKEN ROCK	75	77
-	-	L	-	LIMESTONE	77	98

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STAND STEEL PIPE NEW 18.97#/FT PLAIN END SEAMLESS IPSCO ASTMA53B	Surface	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method FLOODED HOLE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	20	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
FF		09-05-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200
Building Overhang		20

Type	Qualifier	Distance
Clearwater Sump		36
Foundation Drain to Clearwater		19
Septic or Holding, or POWTS Tank		150

Comment:

Created On: 10-14-2003 Updated On: 08-13-2019 Review Status: