

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RM324		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner BANGART, KIM						Phone # (920)853-3080		1. Well Location				Fire # (if avail.)											
Mailing Address W2070 SCHNEIDER RD						Town of RANTOUL						W2070											
City HILBERT						State WI		Zip Code 54129				Street Address or Road Name and Number W2070 SCHNEIDER RD											
County Calumet		Co. Permit #		Notification #		Completed 09-05-2003		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) ROGER WEBER				Lic. # 99		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1117 °N -88.1415 °W				Method Code GCD013									
Address WEBER WELL DRILLING CHILTON WI 53014				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 17 19 N 20 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
						Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
10		Surface		20		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				R - C -		RED CLAY		Surface		58							
6		20		98						- - Y -		SAND & GRAVEL		58		75							
										- B L -		BROKEN ROCK		75		77							
										- - L -		LIMESTONE		77		98							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				15 in. above grade									
6		BLACK STAND STEEL PIPE NEW 18.97#/FT PLAIN END SEAMLESS IPSO ASTM A53B				Surface		77		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 55 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method FLOODED HOLE														Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
PUDDLED CLAY				Surface		20																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														FF						09-05-2003			
														Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200	Clearwater Sump		36
Building Overhang		20	Foundation Drain to Clearwater		19
			Septic or Holding, or POWTS Tank		150

Comment:

Created On: 10-14-2003

Updated On: 08-13-2019

Review Status: