

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RM325		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner SMITH, ROB						Phone # (920)894-4347		1. Well Location				Fire # (if avail.)											
Mailing Address 420 FIELDSTONE CT						Town of NEW HOLSTEIN						Street Address or Road Name and Number PLYMOUTH TRL											
City KIEL				State WI		Zip Code 53042																	
County Calumet		Co. Permit #		Notification #		Completed 09-08-2003		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) ROGER WEBER				Lic. # 99		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address WEBER WELL DRILLING CHILTON WI 53014				Well Plan Approval #				NE SW		Section 34		Township 17 N		Range 20 E									
				Approval Date (mm-dd-yyyy)				or Govt Lot #		Township 17 N		Range 20 E											
Hicap Permanent Well #			Common Well #			Specific Capacity 1.3				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
3. Well serves 1 # of BARN						Hicap Well ? No																	
Private, potable						Hicap Property ? No																	
Heat Exchange ___ # of drillholes						Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		20		Rotary - Mud Circulation				Rotary - Air				- - P G		STONEY HARDPAN		Surface		45			
6		20		217		Yes Rotary - Air & Foam				Yes				- - C -		CLAY		45		69			
Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Rotary - Air & Foam				- - S -				SAND		69		71					
						Drill-Through Casing Hammer				- - P G				STONEY HARDPAN		71		95					
						Reverse Rotary				- - G G				GRAVEL & BOULDERS		95		112					
						Cable-tool Bit ___ in. dia...				- B L -				BROKEN ROCK		112		114					
						Dual Rotary				- - L -				LIMESTONE		114		218					
						Temp. Outer Casing ___ in. dia																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				16 in. above grade									
6		BLACK STAND STEEL PIPE NEW 18.97#/FT PLAIN END SEAMLESS IPSO ASTM A53B				Surface		114		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 75 ft. below surface				Disinfected ? Yes									
										Pumping at 20 GP M for 24 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method FLOODED HOLE														Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
DRILL CUTTINGS				Surface		20				FF						09-08-2003							
										Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		60	Animal Barn Pen		60
			Animal Yard - Include Hutches		70

Comment:

Created On: 10-14-2003

Updated On: 10-14-2003

Review Status: