Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RM326

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GOESER, MIKE	Phone #: (920)921-0332
Mailing Address: N7182 KRAMER CT	
City: FOND DU LAC	State: WI Zip Code: 54935
County: Fond du Lac	Co. Permit #:
Notification #:	Completed: 09-09-2003
Well Constructor (Business Name): ROGER WEBER	Lic. #: 99
Facility ID # (Public Wells):	
Address: WEBER WELL DRILLING CHILTON WI 53014	Well Plan Approval #:
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.3	

1. Well Location

Town of TAYCHEEDAH

Fire # (if avail.):

Street Address or Road Name and Number: N8366 PARK RIDGE CT

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.8435 °N -88.3687 °W

Method Code: GCD013

SW	NE	Section	Township	Range
or Govt Lot #		20	16 N	18 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	7
6	7	58

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	RED CLAY	Surface	7
-	-	S	-	SAND	7	17
-	-	C	S	SANDY CLAY	17	29
G	-	C	-	GRAY CLAY	29	42
-	-	L	-	LIMESTONE	42	44
U	-	H	L	BLUE SHALE & LIMESTONE LAYERS	44	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STAND STEEL PIPE-NEW 18.97#/FT PE SEAMLESS IPSCO TUBULAR ASTMA53 GR B	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method FLOODED HOLE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	7	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
FF		09-09-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Overhang		15
Clearwater Sump		27

Type	Qualifier	Distance
Foundation Drain to Clearwater		14
Sewer - Building Sanitary		62
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 10-13-2003 Updated On: 10-08-2019 Review Status: