Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RN135

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: S & K PUMP & PLUMBING			Phone #: (262)782-7190
Mailing Address: 20880 W ENTERPRISE D			
City: BROOKFIELD	State: WI	Zip Code: 53045	
County: Washington	Co. Permit #:	Notification #:	Completed: 09-03-2003

Well Constructor (Business Name): MICHAEL HARTMAN	Lic. #: 436	Facility ID # (Public Wells):	
Address: MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ADDISON

Fire # (if avail.)

Street Address or Road Name and Number: 6274 HWY 175

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.4199 °N -88.374 °W	Method Code: GCD013		
NE SW or Govt Lot #	Section: 17	Township: 11 N	Range: 18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	200

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	C	SAND, GRAVEL, CLAY	Surface	12
-	-	Y	-	SAND, GRAVEL	12	48
-	-	Y	C	SAND, GRAVEL, CLAY	48	65
-	-	S	-	SAND	65	117
-	-	Y	-	SAND, GRAVEL	117	125
-	-	L	-	LIMESTONE	125	180
U	-	H	-	BLUE SHALE	180	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	0.280 A 53 GRB SAWHILL STEEL WELDED	Surface	125
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

9. Static Water Level
27 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 15 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NO WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		09-04-2003
Drill Rig Operator	Lic or Reg #	Date Signed
MA		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Foundation Drain to Clearwater		13
Building Overhang		12	Sewer - Building Sanitary		35
Clearwater Sump		55	Septic or Holding, or POWTS Tank		72

Comment:

Created On: 10-08-2003 Updated On: 07-05-2019 Review Status: