

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN135		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner S & K PUMP & PLUMBING Phone # (262)782-7190						1. Well Location				Fire # (if avail.)	
Mailing Address 20880 W ENTERPRISE D						Town of ADDISON					
City BROOKFIELD State WI Zip Code 53045						Street Address or Road Name and Number 6274 HWY 175					
County Washington		Co. Permit #		Notification #		Completed 09-03-2003		Subdivision Name		Lot #	Block #
Well Constructor (Business Name) MICHAEL HARTMAN				Lic. # 436	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.4199 °N -88.374 °W		Method Code GCD013		
Address MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218				Well Plan Approval #		NE SW	Section 17	Township 11 N	Range 18 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type New Well of previous unique well # constructed in					
3. Well serves 1 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? NEW HOME					
Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
6	Surface	200	Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
- - Y C		SAND, GRAVEL, CLAY				Surface		12			
- - Y -		SAND, GRAVEL				12		48			
- - Y C		SAND, GRAVEL, CLAY				48		65			
- - S -		SAND				65		117			
- - Y -		SAND, GRAVEL				117		125			
- - L -		LIMESTONE				125		180			
U - H -		BLUE SHALE				180		200			
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	9. Static Water Level			11. Well Is		
6	0.280 A 53 GRB SAWHILL STEEL WELDED			Surface	125	27 ft. below ground surface			18 in. above grade		
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)	10. Pump Test			Developed ? Yes		
						Pumping level 80 ft. below surface			Disinfected ? Yes		
						Pumping at 15 GP M for 4 Hrs.			Capped ? Yes		
						Pumping Method ?					
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
CRUMBLES		Surface									
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? No NO WELL											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
MH								09-04-2003			
Drill Rig Operator						Lic or Reg #		Date Signed			
MA											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Foundation Drain to Clearwater		13
Building Overhang		12	Sewer - Building Sanitary		35
Septic or Holding, or POWTS Tank		72	Clearwater Sump		55

Comment:

Created On: 10-08-2003

Updated On: 07-05-2019

Review Status: