Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RN146

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CAMPANELLI, ANTHONY			Phone #: (414)541-2421
Mailing Address: 3981 S 75TH ST			
City: MILWAUKEE	State: WI	Zip Code: 53220	
County: Washington	Co. Permit #:	Notification #:	Completed: 09-03-2003

1. Well Location
Town of RICHFIELD
Fire # (if avail.):
Street Address or Road Name and Number: 3718 WATRECRESS CT
Subdivision Name: WINDEMERE | Lot #: 5 | Block #:

Well Constructor (Business Name): MICHAEL HARTMAN	Lic. #: 436	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 43.2214 °N -88.2227 °W	Method Code: GCD013
Address: MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218		Well Plan Approval #:	NE NE or Govt Lot #:	Section: 27	Township: 9 N	Range: 19 E
		Approval Date (mm-dd-yyyy):				
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2				

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NEW HOME

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	156

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	GRAVEL, SAND	Surface	35
-	-	C	S	SANDY CLAY	35	153
-	-	G	-	GRAVEL	153	156

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	0.280 A 53 GRB SAWHILL STEEL WELDED	Surface	156
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 50 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NO WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		09-04-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Foundation Drain to Clearwater		16
Clearwater Sump		17	Sewer - Building Sanitary		35

Comment:

Created On: 10-08-2003 Updated On: 07-08-2019 Review Status: