

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN146		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner CAMPANELLI, ANTHONY						Phone # (414)541-2421		1. Well Location				Fire # (if avail.)			
Mailing Address 3981 S 75TH ST						Town of RICHFIELD									
City MILWAUKEE						State WI		Zip Code 53220							
County Washington		Co. Permit #		Notification #		Completed 09-03-2003		Subdivision Name WINDEMERE				Lot # 5			
Well Constructor (Business Name) MICHAEL HARTMAN				Lic. # 436		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.2214 °N -88.2227 °W				Method Code GCD013			
Address MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 27 9 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 2											
3. Well serves 1 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 156		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
						Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... - - Y - GRAVEL, SAND Surface 35 - - C S SANDY CLAY 35 153 - - G - GRAVEL 153 156					
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification 0.280 A 53 GRB SAWHILL STEEL WELDED Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 156		9. Static Water Level 35 ft. below ground surface		11. Well Is 18 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes			
										Pumping level 60 ft. below surface Pumping at 50 GP M for 4 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material CRUMBLES		From (ft.) Surface		To (ft.)		# Sacks Cement				12. Notified Owner of need to fill & seal ?					
										Filled & Sealed Well(s) as needed? NO					
										13. Constructor / Supervisory Driller		Lic #			
										MH		Date Signed 09-04-2003			
										Drill Rig Operator		Lic or Reg #			
										RH		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Foundation Drain to Clearwater		16
Clearwater Sump		17	Sewer - Building Sanitary		35

Comment:

Created On: 10-08-2003

Updated On: 07-08-2019

Review Status: