Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RN171

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BADGER HOMES, VAN LAANEN, CHAD			Phone #: (262)798-8010
Mailing Address: 2236A BLUEMOUND RD			
City: WAUKESHA	State: WI	Zip Code: 53186	
County: Ozaukee	Co. Permit #:	Notification #:	Completed: 09-04-2003

1. Well Location

City of MEQUON

Fire # (if avail.):

Street Address or Road Name and Number: 10562 N CEDARBURG RD

Subdivision Name	Lot #	Block #
CSM #2773	2	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MICHAEL HARTMAN	436	

Latitude / Longitude in Decimal Degree (DD): 43.2106 °N -87.9745 °W

Method Code: GCD013

Well Plan Approval #:

NE	SW	Section	Township	Range
or Govt Lot #		26	9 N	21 E

Address: MICHAEL HARTMAN WELL DRLG & PUMP I
NORTH LAKE WI 53064-0218

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.7

Reason for replaced or reconstructed well ?

NEW HOME

3. Well serves 1 # of HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	185

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	SURFACE CLAY	Surface	8
-	-	S	-	SAND	8	35
-	-	P	-	HARDPAN	35	94
-	-	L	-	LIMESTONE	94	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	0.280 A 53 GRB SAWHILL STEEL WELDED	Surface	94
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

57 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 40 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NO WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		09-05-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		28	Collector Sewer - San or Storm		120
Clearwater Sump		70	Foundation Drain to Clearwater		29
			Sewer - Building Sanitary		35

Comment:

Created On: 10-08-2003 Updated On: 07-15-2019 Review Status: