Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RN185

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	WILL, BRAD
Phone #	(262)784-6262
Mailing Address	14525 W MEADOWSHIRE
City	NEW BERLIN
State	WI
Zip Code	53151
County	Waukesha
Co. Permit #	
Notification #	
Completed	09-04-2003
Well Constructor (Business Name)	MICHAEL HARTMAN
Lic. #	436
Facility ID # (Public Wells)	
Address	MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	2.2

1. Well Location

Town of DELAFIELD	
Fire # (if avail.)	
Street Address or Road Name and Number	N41 W28814 IMPERIAL DR
Subdivision Name	PRAIRIE WIND FARMS
Lot #	3
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.0923 °N -88.3197 °W
Method Code	GCD013
SW SW or Govt Lot #	
Section	1
Township	7 N
Range	18 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44
5	44	47

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Air ..... — No

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	C	SAND, GRAVEL, CLAY	Surface	10
-	-	C	S	SANDY CLAY	10	38
-	-	Y	-	SAND, GRAVEL	38	47

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	.280 A53B SAWHILL STEEL WELDED	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	#25 SLOT COOK	44	47

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 20 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NO WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		09-04-2003
Drill Rig Operator	Lic or Reg #	Date Signed
MA		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Foundation Drain to Clearwater		16
Collector Sewer - San or Storm		75	Sewer - Building Sanitary		45

Comment:

Created On: 10-08-2003 Updated On: 07-12-2019 Review Status: