

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN196		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner NELS ANDERSON ENTERPRISE						Phone # (262)966-1000		1. Well Location				Fire # (if avail.)							
Mailing Address N76 W30500 HWY VV						City of MUSKEGO						Street Address or Road Name and Number							
City HARTLAND						State WI		Zip Code 53029				S73 W19309 LOCHCREST							
County Waukesha		Co. Permit #		Notification #		Completed 09-03-2003		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) MICHAEL HARTMAN				Lic. # 436		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.9121 °N -88.1557 °W				Method Code GCD013					
Address MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218				Well Plan Approval #				SW NE Section Township Range or Govt Lot # 8 5 N 20 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OUT OF WATER									
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 2.7				Construction Type Drilled									
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
6		Surface		111		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - C -		CLAY		Surface		47			
5		111		114						- - Y -		SAND & GRAVEL		47		80			
										- - P -		HARDPAN		80		106			
										- - Y -		SAND & GRAVEL		106		114			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		69 ft. below ground surface				18 in. above grade					
6		.280 A53B SAWHILL STEEL WELDED				Surface		111		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
5		#18 SLOT COOK				111		114		Pumping at 30 GP M for 4 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method MOUNDED												Filled & Sealed Well(s) as needed? No BY PLUMBER							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
CRUMBLES		Surface																	
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												MH						09-04-2003	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												JB						09-17-2003	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		16	Collector Sewer - San or Storm		66
Clearwater Sump		35	Foundation Drain to Clearwater		20
			Sewer - Building Sanitary		15

Comment:

Created On: 10-08-2003

Updated On: 07-11-2019

Review Status: