

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN215		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner CARTER, LYMAN						Phone # (813)348-9277		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 1088						Town of PHELPS						5234	
City EAGLE RIVER						State WI		Zip Code 54521				Street Address or Road Name and Number SUGAR MAPLE RD	
County Vilas		Co. Permit #		Notification #		Completed 07-01-2003		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) RICHARD E HEDBERG				Lic. # 490		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.0995 °N -89.0794 °W				Method Code GCD013	
Address HEDBERG WELL DRILLING CONOVER WI 54519-9215				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE Section Township Range or Govt Lot # 4 23 42 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7									
3. Well serves 1 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		64						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) - - I S TOPDIRF-SAND Surface 6 - - Z - GRAVEL & CLAY 6 50 R - C - RED CLAY 50 58 - W Y - WATER BEARING SAND & GRAVEL 58 64			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		STEEL;18.97#;AST-53 IPSCO;WELDED				Surface		61		28 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
5.63		JOHNSON, S.S. #15				61		64		12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
				Surface									
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
REH										07-01-2003			
Drill Rig Operator								Lic or Reg #		Date Signed			
DH										07-02-2003			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Shoreline/Pool		140

Comment:

Created On: 08-11-2003

Updated On: 06-30-2020

Review Status: