

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN245		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner MCBEATH, MARGARET Phone # (608)233-2011						1. Well Location Fire # (if avail.)					
Mailing Address 13 PARK LAWN PL						Town of LAND O LAKES 6431					
City MADISON State WI Zip Code 53705						Street Address or Road Name and Number FOREST LAKE RD					
County Vilas		Co. Permit #		Notification #		Completed 05-19-2003		Subdivision Name Lot # Block #			
Plat of Forest LK											
Well Constructor (Business Name) RICHARD E HEDBERG				Lic. # 490		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.158 °N -89.3649 °W Method Code GCD013			
Address HEDBERG WELL DRILLING CONOVER WI 54519-9215				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 34 43 N 9 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? IRON WATER Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2							
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock		Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
6 Surface 83				- - I G TOPSOIL/GRAVEL Surface 18							
				- - S - DRY SAND 18 22							
				- J S - WET SAND IRON 22 28							
				- - P - HARDPAN 28 32							
				- - Z - CLAY/GRAVEL 32 68							
				- W S - WATER SAND 68 83							
6. Casing, Liner, Screen											
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		9. Static Water Level 11. Well Is							
6 AST53 STL 18.97 IPSCO WELD		Surface 80		22 ft. below ground surface 12 in. above grade							
Dia. (in.) Screen type, material & slot size		From (ft.) To (ft.)		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
5.63 SS JOHNSON 12#		80 83		Pumping level 35 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material		From (ft.) To (ft.) # Sacks Cement		12. Notified Owner of need to fill & seal ?							
		Surface		Filled & Sealed Well(s) as needed? Yes							
13. Constructor / Supervisory Driller Lic # Date Signed											
REH 05-20-2003											
Drill Rig Operator Lic or Reg # Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Shoreline/Pool		90
Building Overhang		12	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 07-11-2003

Updated On: 06-30-2020

Review Status: