Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RN245

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCBEATH, MARGARET			Phone #: (608)233-2011
Mailing Address: 13 PARK LAWN PL			
City: MADISON	State: WI	Zip Code: 53705	
County: Vilas	Co. Permit #:	Notification #:	Completed: 05-19-2003

Well Constructor (Business Name): RICHARD E HEDBERG	Lic. #: 490	Facility ID # (Public Wells):	
Address: HEDBERG WELL DRILLING, CONOVER WI 54519-9215		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LAND O LAKES

Fire # (if avail.): 6431

Street Address or Road Name and Number: FOREST LAKE RD

Subdivision Name: PLAT OF FOREST LK	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 46.158 °N -89.3649 °W
Method Code: GCD013

NW or Govt Lot #	NE	Section	Township	Range
		34	43 N	9 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
IRON WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	83

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	G	TOPSOIL/GRAVEL	Surface	18
-	-	S	-	DRY SAND	18	22
-	J	S	-	WET SAND IRON	22	28
-	-	P	-	HARDPAN	28	32
-	-	Z	-	CLAY/GRAVEL	32	68
-	W	S	-	WATER SAND	68	83

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	AST53 STL 18.97 IPSCO WELD	Surface	80
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5.63	SS JOHNSON 12#	80	83

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
22 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
REH		05-20-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Shoreline/Pool		90
Building Overhang		12	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 07-11-2003 Updated On: 06-30-2020 Review Status: