

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN291		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SZMANIA, JIM						Phone # (715)272-1740		1. Well Location				Fire # (if avail.)					
Mailing Address 3926 INDIAN LK RD						Town of SUGAR CAMP						3926					
City RHINELANDER						State WI		Zip Code 54501				Street Address or Road Name and Number INDIAN LAKE RD					
County Oneida		Co. Permit #		Notification #		Completed 01-27-2004		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) ERIC SCHUETTE				Lic. # 6673		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8104 °N -89.3142 °W				Method Code GCD013					
Address RHINELANDER WI 54501				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 1 38 N 9 E		2. Well Type Replacement of previous unique well # constructed in 1999 Reason for replaced or reconstructed well ? PLUGGED POINT Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		39						T - S -		SAND & CLAY		Surface		12	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - S -		SAND DRY		12		18	
										O W S -		FINE WATER SAND		18		39	
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 18 ft. below ground surface				11. Well Is 15 in. above grade			
6		STEEL 18.97 A353 IPSO-WELDED				Surface		35		10. Pump Test Pumping level 30 ft. below surface Pumping at 5 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		GS SS 10#				35		39									
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement Surface												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller Lic # Date Signed ES 01-29-2004 Drill Rig Operator Lic or Reg # Date Signed REH 01-28-2004																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		5
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 03-23-2004

Updated On: 06-30-2020

Review Status: