Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: RN971

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	RICHARDS, JOE
Phone #	(608)938-1513
Mailing Address	W3610 NYE RD
City	MONTICELLO
State	WI
Zip Code	53570
County	Richland
Co. Permit #	
Notification #	
Completed	07-21-2003

1. Well Location

Town of ITHACA

Fire # (if avail.)

Street Address or Road Name and Number: 29587 BLUE BIRD LN

Subdivision Name | Lot # | Block #

Well Constructor (Business Name)	DONALD HERBECK
Lic. #	229
Facility ID # (Public Wells)	
Address	A-D WELL & PUMP SERVICE SEXTONVILLE WI 53584
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	2.5

Latitude / Longitude in Decimal Degree (DD): 43.3348 °N -90.2792 °W
Method Code: GPS008

SW	NE	Section	Township	Range
or Govt Lot #		20	10 N	2 E

2. Well Type Replacement

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?
NONCOMPLYING TIN CASED WE

Construction Type: Drilled

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	59
6	59	149

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 12depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	M	S	S	YELLOW SAND	Surface	15
E	S	H	H	SOFT GREEN SHALE	15	43
E	H	H	H	FIRM GREEN SHALE	43	87
I	S	N	-	SOFT WHITE SANDSTONE	87	149

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SCH 40 ASTM A53-B 6.625 X .280 PE L21 HT CST NSF 61 WHEATLAND USA	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
66 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
21 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method: TREMIE-PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	59	25 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes
OLD WELL ABANDONED BY A-D

13. Constructor / Supervisory Driller	Lic #	Date Signed
DAH		08-04-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Collector Sewer - San or Storm	>	25	Foundation Drain to Sewer	>	8
			Sewer - Building Sanitary	>	8

Comment:

Created On: 08-21-2003 Updated On: 04-23-2020 Review Status: