Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RN973

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TREBUS, MARK			Phone #: (608)647-9963
Mailing Address: 23009 CO HWY AA			
City: RICHLAND CENTER	State: WI	Zip Code: 53581	
County: Richland	Co. Permit #:	Notification #:	Completed: 07-28-2003
Well Constructor (Business Name): DONALD HERBECK	Lic. #: 229	Facility ID # (Public Wells):	
Address: A-D WELL & PUMP SERVICE, SEXTONVILLE WI 53584		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2	

1. Well Location

Town of RICHLAND

Fire # (if avail.):

Street Address or Road Name and Number: CO HWY AA

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NE or Govt Lot #:	Section: 9	Township: 10 N	Range: 1 E

2. Well Type New Well — TY775 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	50.5
6	50.5	159

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 10in. dia... No

Dual Rotary .....

Yes Temp. Outer Casing 10in. dia

Yes Removed? 6depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
E	S	H	H	SOFT SHALE ROCK	Surface	35
G	H	H	H	FIRM SHALE ROCK	35	93
I	S	N	-	SOFT WHITE SANDSTONE	93	159

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53-B SCH 40 6.625 X .280 PE L21 HT CST NSF 61 WHEATLAND USA	Surface	50.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

105 ft. below ground surface

10. Pump Test

Pumping level 110 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE-PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	50.5	40 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DAH		08-04-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	>	1200

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	12/06/2006	BENTONITE 0-159' 52 SACKS USED	BUILDING ADDITION

Created On: 08-21-2003 Updated On: 01-26-2007 Review Status: