

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RN973		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner TREBUS, MARK						Phone # (608)647-9963		1. Well Location				Fire # (if avail.)											
Mailing Address 23009 CO HWY AA						Town of RICHLAND						Street Address or Road Name and Number CO HWY AA											
City RICHLAND CENTER				State WI		Zip Code 53581																	
County Richland		Co. Permit #		Notification #		Completed 07-28-2003		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) DONALD HERBECK				Lic. # 229		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address A-D WELL & PUMP SERVICE SEXTONVILLE WI 53584				Well Plan Approval #				°N		°W		NW NE Section Township Range or Govt Lot # 9 10 N 1 E											
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 2				2. Well Type New Well TY775 replaces this well of previous unique well # constructed in															
3. Well serves 1 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								Reason for replaced or reconstructed well ? Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		50.5		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 10in. dia... No Dual Rotary Yes Temp. Outer Casing 10in. dia Yes Removed? 6depth ft. (If NO explain on back side)				E S H H		SOFT SHALE ROCK		Surface		35							
6		50.5		159						G H H H		FIRM SHALE ROCK		35		93							
										I S N -		SOFT WHITE SANDSTONE		93		159							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		105 ft. below ground surface				12 in. above grade									
6		ASTM A53-B SCH 40 6.625 X .280 PE L21 HT CST NSF 61 WHEATLAND USA				Surface		50.5		10. Pump Test Pumping level 110 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material Method TREMIE-PUMPED												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
NEAT CEMENT GROUT				Surface		50.5		40 S		13. Constructor / Supervisory Driller				Lic #		Date Signed							
										DAH						08-04-2003							
										Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	>	1200

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	12/06/2006	BENTONITE 0-159' 52 SACKS USED	BUILDING ADDITION

Created On: 08-21-2003

Updated On: 01-26-2007

Review Status: