

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RO960		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner K S DEVELOPMENT						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 6520 HIDDEN CREEK RD						Town of CALEDONIA																	
City RACINE						State WI		Zip Code 53401				Street Address or Road Name and Number 6520 HIDDEN CREEK RD											
County Racine		Co. Permit #		Notification #		Completed 11-11-2003		Subdivision Name RIVER MDW				Lot # Block #											
Well Constructor (Business Name) WILLIAM MANDE				Lic. # 6383		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7869 °N -87.8606 °W				Method Code GCD013									
Address HOOVER WELL DRLG UNION GROVE WI 53182				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 23 4 N 22 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
						Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 3																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		40		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Y - C -		YELLOW CLAY		Surface		12					
6		40		110								- - P -		HARDPAN		12		25					
												- - L -		LIMESTONE		25		110					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				12 in. above grade									
6		SAWHILL A53B PE 18.97 PPF				Surface		40		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 31 ft. below surface				Disinfected ? Yes									
										Pumping at 30 GP M for 8 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method BRADENHEAD														Filled & Sealed Well(s) as needed? NON-OBSERVED									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT GROUT				Surface		40		16 S						WM						12-02-2003			
														Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Collector Sewer - San or Storm		120	Foundation Drain to Clearwater		25

Comment:

Created On: 01-07-2004

Updated On: 06-28-2019

Review Status: