Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RQ293

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHOENICK, BILL	Phone #
Mailing Address: 4831 GRIFFITH AVE	
City: WISCONSIN RAPIDS	State: WI — Zip Code: 54494
County: Wood	Co. Permit #: — Notification #: 40962244 — Completed: 07-06-2011
Well Constructor (Business Name): ROTH PLBG & WELL DRLG	Lic. #: 5857 — Facility ID # (Public Wells):
Address: 618 HWY 73S, NEKOOSA WI 54457	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7.5

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.):

Street Address or Road Name and Number: 4831 GRIFFITH AVE

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW	SW	Section	Township	Range
or Govt Lot #		26	22 N	6 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

OLD WELL FAILING

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	47.6

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	32
-	-	X	-	CLAY & SAND	32	34
-	N	S	-	FINE SAND	34	37
-	A	Y	-	CRS SAND & GRAVEL	37	47.6

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	BARZEL A53 6.625X.280 GR BE HEAT #123633	Surface	44.6
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	WELDED JOHNSON S.S. 12 SLOT	44.6	47.6

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 26 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KR		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Drain - Sanitary		24
Building Overhang		12
Wastewater Sump		26
Sewer - Building Sanitary		42
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 08-16-2011 Updated On: 08-16-2011 Review Status: