

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RQ610		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HALL, KEN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address E9454 INNISBROOK								Town of DELLONA											
City WISCONSIN DELLS						State WI		Zip Code 53965											
County Sauk		Co. Permit #		Notification #		Completed 12-29-2003		Street Address or Road Name and Number BAY HILL CT											
Subdivision Name CHRISTMAS MT GOLF EST						Lot #		Block #											
Well Constructor (Business Name) MICHAEL L COONS						Lic. # 91		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W							
Address COONS WELL DRILLING BARABOO WI 53913-9438						Well Plan Approval #		NW SW Section Township Range or Govt Lot # 13 13 N 5 E		Method Code									
Approval Date (mm-dd-yyyy)								2. Well Type New Well											
Hicap Permanent Well #						Common Well #		Specific Capacity 1				of previous unique well # constructed in							
3. Well serves 1 # of						Hicap Well ? No		Reason for replaced or reconstructed well ?											
Private, potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
8.75 Surface 34									- - S -		SAND		Surface 16						
6 34 120									- - H -		SHALE		16 23						
			Yes Rotary - Mud Circulation Yes Rotary - Air Yes Rotary - Air & Foam Yes Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Yes Temp. Outer Casing 14in. dia Yes Removed? 3depth ft. (If NO explain on back side)						- S N -		SOFT SANDSTONE		23 28						
									I H N -		FIRM WHITE SANDSTONE		28 120						
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				20 in. above grade					
6.625		IPSCO PE 18.97 X .280 A53B				Surface		34		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 49 ft. below surface				Disinfected ? Yes					
										Pumping at 12 GP M for 24 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method TREMIE PUMPED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT				Surface		34		8 S											
Filled & Sealed Well(s) as needed?																			
13. Constructor / Supervisory Driller										Lic #		Date Signed							
MC												03-12-2004							
Drill Rig Operator										Lic or Reg #		Date Signed							
EC																			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary	>	15	Collector Sewer - San or Storm	>	50
Building Overhang	>	6	Wastewater Sump	>	25
Clearwater Sump	>	20	Sewer - Building Sanitary	>	25

Comment:

Created On: 05-06-2004

Updated On: 05-24-2004

Review Status: