

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RR512		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																									
Property Owner VERHAALEN, RON					Phone # (262)512-1308			1. Well Location				Fire # (if avail.)																							
Mailing Address 111 HEIDEL RD					Town of LIND							E2571																							
City THIENSVILLE					State WI		Zip Code 53092					Street Address or Road Name and Number AKRON AVE																							
County Waupaca		Co. Permit #		Notification #			Completed 08-07-2003			Subdivision Name			Lot #		Block #																				
Well Constructor (Business Name) STANLEY JOHNSON				Lic. # 189		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)				Method Code																						
Address JOHNSON WELL DRILLING WAUPACA WI 54981				Well Plan Approval #			°N		°W		NW NW Section Township Range or Govt Lot # 19 21 N 12 E																								
Hicap Permanent Well #				Common Well #		Specific Capacity 2			2. Well Type New Well																										
Heat Exchange ___ # of drillholes				Hicap Well ? No			Hicap Property ? No			Reason for replaced or reconstructed well ?																									
3. Well serves 1 # of Private, potable				Hicap Potable ?			Construction Type Drilled			of previous unique well # constructed in																									
4. Potential Contamination Sources - ON REVERSE SIDE												of previous unique well # constructed in																							
5. Drillhole Dimensions and Construction Method												8. Geology																							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)																	
8		Surface		15		Rotary - Mud Circulation			Rotary - Air			Rotary - Air & Foam			Drill-Through Casing Hammer			Reverse Rotary			Cable-tool Bit ___ in. dia...			Dual Rotary			- Q S - CAVING SAND			Surface			22		
5		15		65		Yes Temp. Outer Casing 8in. dia			Yes Removed? 15depth ft. (If NO explain on back side)			- - P - HARDPAN			22			28																	
3		61		65		28			35			35			50			50			65														
3		61		65		35			50			50			65			65																	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface				12 in. above grade																					
5		STEEL 15# ASTMA53B IPSCO T&C				Surface		61		10. Pump Test				Developed ? Yes																					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 25 ft. below surface				Disinfected ? Yes																					
3		STAINLESS STEEL				61		65		Pumping at 12 GP M for 1 Hrs.				Capped ? Yes																					
7. Grout or Other Sealing Material												Pumping Method ?				Filled & Sealed Well(s) as needed?																			
Method												12. Notified Owner of need to fill & seal ?				Filled & Sealed Well(s) as needed?																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed																	
BENTONITE SLURRY				Surface		15		SJ				08-18-2003		Drill Rig Operator		Lic or Reg #		Date Signed																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		8
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 10-02-2003

Updated On: 10-02-2003

Review Status: