

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RS733		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner FEUKER, JOHN & CATHY						Phone # (715)639-2403		1. Well Location				Fire # (if avail.)											
Mailing Address E1661 300TH AVE						Town of WESTON						Street Address or Road Name and Number											
City ELMWOOD				State WI		Zip Code 54740																	
County Dunn		Co. Permit #		Notification #		Completed 10-23-2003		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) PELKE PLBG HTG & WELL DRLG INC				Lic. # 535		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address N6298 STATE HWY 25 DURAND WI 54736-9105				Well Plan Approval #				°N		°W		NE SW Section Township Range or Govt Lot # 28 27 N 14 W											
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #			Common Well #			Specific Capacity 12			2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONSTRUCTION														
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?							Construction Type Drilled										
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		54		Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 10depth ft. (If NO explain on back side)				R - C -		RED CLAY		Surface		10							
6		54		120						E - H -		GREEN SHALE		10		50							
										T - H -		BROWN SHALE		50		110							
										T - N -		BROWN SANDSTONE		110		120							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		65 ft. below ground surface				24 in. above grade									
6		NEW BLK ST T&C ASTM A53 GR B 19.45 LBS IPSCO USA				Surface		54		10. Pump Test Pumping level 66 ft. below surface Pumping at 12 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material Method TREMIE PIPE PRESSURE														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No DOES NOT APPLY									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
PORTLAND CEMENT				Surface		54		15 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed							
														MW		10-29-2003							
														Drill Rig Operator		Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang	>	40
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 11-20-2003

Updated On: 11-20-2003

Review Status: