

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RS735		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner JACOBSEN, JIM						Phone # (715)235-2909		1. Well Location				Fire # (if avail.)			
Mailing Address N7639 CO RD F						Town of SHERMAN						N7639			
City MENOMONIE						State WI		Zip Code 54751				Street Address or Road Name and Number N7639 CO RD F			
County Dunn		Co. Permit #		Notification #		Completed 10-24-2003		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) PELKE PLBG HTG & WELL DRLG INC				Lic. # 535		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address N6298 STATE HWY 25 DURAND WI 54736-9105				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 35 29 N 13 W		2. Well Type Replacement				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.4		Reason for replaced or reconstructed well ? BAD WATER				Construction Type Drilled					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Heat Exchange ___ # of drillholes				Hicap Potable ?			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
6		Surface		70		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... - - C - CLAY Surface 40 - F N - FRACTURES SANDSTONE 40 55 T H N - HARD BROWN SANDSTONE 55 70					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		NEW BLK ST T&C ASTM A53 GR B 19.45 LBS IPSCO USA				Surface		60		45 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
										16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material															
Method GRAVITY FED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?							
GRANULAR BENTONITE		Surface						Filled & Sealed Well(s) as needed? Yes							
13. Constructor / Supervisory Driller															
MW		Lic #		Date Signed		10-29-2003		Drill Rig Operator							
		Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Downspout/Yard Hydrant	>	25
Building Overhang	>	25	Sewer - Building Sanitary	>	25
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 11-20-2003

Updated On: 11-20-2003

Review Status: