

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RX590		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KAMLA, ANDY						Phone # (630)665-4424		1. Well Location				Fire # (if avail.)					
Mailing Address S3581 PINE KNOLL CT						Town of FAIRFIELD						S3581					
City BARABOO						State WI		Zip Code 53913				Street Address or Road Name and Number					
S3581 PINE KNOLL CT						Subdivision Name				Lot #		Block #					
County Sauk		Co. Permit #		Notification #		Completed 12-19-2001		BENT TREE				78					
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
ACE WELL DRILLING LLC				393				43.5152 °N -89.7245 °W				GCD013					
Address PO BOX 238 WISCONSIN DELLS WI 53965				Well Plan Approval #		NW SE		Section 13		Township 12 N		Range 6 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
3. Well serves 1 # of HOME				Hicap Well ? No													
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		100		No Rotary - Mud Circulation		No		- - S -		Sand		Surface		33	
						No Rotary - Air		No		- - C -		Clay		33		51	
						No Rotary - Air & Foam		No		- - X -		Sand & Clay		51		75	
						Yes Drill-Through Casing Hammer				- - Y -		Sand & Gravel		75		100	
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						Dual Rotary											
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		STD. BLK. PIPE, .280 WALL, WLD., JNTS. A 53 SAWHILL				Surface		97		35 ft. below ground surface				18 in. above grade			
5		RISER PIPE WITH PACKER				93		97		10. Pump Test				Developed ? Yes			
										Pumping level 65 ft. below surface				Disinfected ? Yes			
										Pumping at 20 GP M for 1 Hrs.				Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?							
5		#20 SLOTTED STAINLESS				97		100									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method												Filled & Sealed Well(s) as needed?					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed	
Granular bentonite				Surface				4		JVG						01-02-2002	
										Drill Rig Operator				Lic or Reg #		Date Signed	
										SUK						01-02-2002	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		84	Septic or Holding, or POWTS Tank		77

Comment:

Created On: 06-17-2002

Updated On: 03-30-2020

Review Status: APPROVED