

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SA399		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WROBLEWSKI, STEVEN						Phone # (715)295-0015		1. Well Location				Fire # (if avail.)			
Mailing Address 4337 MICHAEL COURT						Town of PLOVER						Street Address or Road Name and Number 4337 MICHAEL COURT			
City PLOVER				State WI		Zip Code 54467		Subdivision Name				Lot #		Block #	
County Portage		Co. Permit #		Notification #		Completed 10-19-2004		Latitude / Longitude in Decimal Degree (DD) 44.464 °N -89.5904 °W				Method Code GCD013			
Well Constructor (Business Name) DONALD J FIRKUS SR				Lic. # 222		Facility ID # (Public Wells)		SE NE Section Township Range or Govt Lot # 19 23 N 8 E		2. Well Type Replacement					
Address FIRKUS WELL DRILLING AMHERST WI 54406-9189				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 5		Reason for replaced or reconstructed well ? Point Quit							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology						
6 Surface 60			No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) B - I - Black, Soil-Organic Surface 1 T - S - Tan/Brown, Sand 1 36 T - Y - Tan/Brown, Sand & Gravel 36 48 O - Y - Orange, Sand & Gravel 48 53 T - S - Tan/Brown, Sand 53 60						
6. Casing, Liner, Screen															
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)			9. Static Water Level			11. Well Is			
6			A53B 18.97 Sawhill Weld			Surface 16			39 ft. below ground surface			12 in. above grade			
6			A53B 18.97 Ipsco Weld			16 56			10. Pump Test			Developed ? Yes			
Dia. (in.)			Screen type, material & slot size			From (ft.) To (ft.)			Pumping level 42 ft. below surface			Disinfected ? Yes			
6			Stainless Steel Telescoping 12 slot			56 60			Pumping at 15 GP M for 2 Hrs.			Capped ? Yes			
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.) To (ft.) # Sacks Cement		12. Notified Owner of need to fill & seal ?									
Surface						Filled & Sealed Well(s) as needed? Yes Owner given form									
13. Constructor / Supervisory Driller								Lic #		Date Signed					
DF										10-20-2004					
Drill Rig Operator								Lic or Reg #		Date Signed					
DJFJ										10-20-2004					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		6
			Septic or Holding, or POWTS Tank		52

Comment:

Created On: 11-05-2004

Updated On: 05-07-2020

Review Status: APPROVED