Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: SA399

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WROBLEWSKI, STEVEN	Phone #: (715)295-0015
Mailing Address: 4337 MICHAEL COURT	
City: PLOVER	State: WI — Zip Code: 54467
County: Portage	Co. Permit #:
Notification #	Completed: 10-19-2004
Well Constructor (Business Name): DONALD J FIRKUS SR	Lic. #: 222
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: FIRKUS WELL DRILLING, AMHERST WI 54406-9189	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 5	

1. Well Location

Town of PLOVER

Fire # (if avail.)

Street Address or Road Name and Number: 4337 MICHAEL COURT

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.464 °N -89.5904 °W	GCD013

SE NE or Govt Lot #	Section	Township	Range
	19	23 N	8 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: Point Quit

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
B - I -	Black, Soil-Organic	Surface	1
T - S -	Tan/Brown, Sand	1	36
T - Y -	Tan/Brown, Sand & Gravel	36	48
O - Y -	Orange, Sand & Gravel	48	53
T - S -	Tan/Brown, Sand	53	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B 18.97 Sawhill Weld	Surface	16
6	A53B 18.97 Ipsco Weld	16	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	Stainless Steel Telescoping 12 slot	56	60

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

39 ft. below ground surface

10. Pump Test

Pumping level 42 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

Owner given form

13. Constructor / Supervisory Driller	Lic #	Date Signed
DF		10-20-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJFJ		10-20-2004

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Type	Qualifier	Distance
Building Overhang		6
Septic or Holding, or POWTS Tank		52

Comment:

Created On: 11-05-2004 Updated On: 05-07-2020 Review Status: APPROVED