

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SA400		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MAKUSKI, EILEEN						Phone # (715)824-3362		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 253						Town of AMHERST						Street Address or Road Name and Number 9632 CTY B					
City AMHERST				State WI		Zip Code 54406											
County Portage		Co. Permit #		Notification #		Completed 10-27-2004		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) DONALD J FIRKUS SR				Lic. # 222		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address FIRKUS WELL DRILLING AMHERST WI 54406-9189				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 21 23 N 10 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? Point Quit Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.9		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes											
Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) 6		From (ft.) Surface		To (ft.) 71		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)		T Q Y - Tan/Brown, Caving, Sand & Gravel T N S - Tan/Brown, Fine, Sand T M S - Tan/Brown, Medium, Sand		Surface 30 30 50 50 71													
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly A53B 18.99 Paragon Weld				From (ft.) Surface		To (ft.) 67		38 ft. below ground surface				12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.) 6		Screen type, material & slot size 10 slot Stainless Steel Telescoping				From (ft.) 67		To (ft.) 71		10. Pump Test Pumping level 46 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method						Filled & Sealed Well(s) as needed? Owner Given Form											
Kind of Sealing Material		From (ft.) Surface		To (ft.)													
13. Constructor / Supervisory Driller DF Drill Rig Operator LM						Lic #		Date Signed 11-12-2004									
						Lic or Reg #		Date Signed 11-12-2004									
						Date Signed		Date Signed									
						Date Signed		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Landfill		1500
Building Overhang		6	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 11-16-2004

Updated On: 11-18-2004

Review Status: APPROVED