Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SA401

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GREZINSKI, BRUCE & TIFFANY	Phone #: (715)693-6867
Mailing Address: 3200 COUNTRY LANE	
City: MOSINEE	State: WI — Zip Code: 54455
County: Marathon	Co. Permit #: — Notification #: — Completed: 10-29-2004
Well Constructor (Business Name): DONALD J FIRKUS SR	Lic. #: 222 — Facility ID # (Public Wells):
Address: FIRKUS WELL DRILLING, AMHERST WI 54406-9189	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location
Town of GUENTHER
Fire # (if avail.):
Street Address or Road Name and Number: 3200 COUNTRY LANE
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
SW SE or Govt Lot #: — Section: 33 — Township: 26 N — Range: 8 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?
Wanted more water
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	300

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	S	C	Tan/Brown, Non-Caving, Sand, Clayey	Surface	3
U	-	Q	-	Red &Blue Granite Layered	3	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B 18.99 Paragon Weld	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method: Bradenhead

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	40	6 S

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 280 ft. below surface
Pumping at 1.5 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
Old well used for cattle

13. Constructor / Supervisory Driller	Lic #	Date Signed
DF		11-12-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJFJ		11-12-2004

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		64

Type	Qualifier	Distance
Building Overhang		27
Septic or Holding, or POWTS Tank		63

Comment:

Created On: 11-16-2004 Updated On: 08-09-2005 Review Status: APPROVED