Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SA402

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: ZBLEWSKI, RICHARD & SHARON	Phone #: (715)592-2848
Mailing Address: 7095 OLD HWY 18	
City: CUSTER	State: WI — Zip Code: 54423
County: Portage	Co. Permit #: — Notification #: — Completed: 11-01-2004
Well Constructor (Business Name): DONALD J FIRKUS SR	Lic. #: 222 — Facility ID # (Public Wells):
Address: FIRKUS WELL DRILLING, AMHERST WI 54406-9189	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 10

1. Well Location
Town of STOCKTON
Fire # (if avail.):
Street Address or Road Name and Number: 7095 OLD HWY 18
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.5064 °N -89.4319 °W
Method Code: GCD013
NW NE or Govt Lot #: — Section: 5 — Township: 23 N — Range: 9 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?
Old well plugged up
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	75

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	Y	-	Tan/Brown, Soft/Loose, Sand & Gravel	Surface	30
G	H	X	-	Gray, Hard/Firm, Sand & Clay	30	50
T	S	Y	C	Tan/Brown, Soft/Loose, Sand & Gravel, Clayey	50	66
T	S	Y	-	Tan/Brown, Soft/Loose, Sand & Gravel	66	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B 18.99 Paragon Weld	Surface	71
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	12 slot Telescoping Stainless Steel	71	75

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
48 ft. below ground surface

10. Pump Test
Pumping level 49 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes
Owner given form

13. Constructor / Supervisory Driller	Lic #	Date Signed
DF		11-12-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM		11-12-2004

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		86

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 11-16-2004 Updated On: 05-07-2020 Review Status: APPROVED