

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SA402		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ZBLEWSKI, RICHARD & SHARON						Phone # (715)592-2848		1. Well Location				Fire # (if avail.)							
Mailing Address 7095 OLD HWY 18						Town of STOCKTON						Street Address or Road Name and Number 7095 OLD HWY 18							
City CUSTER				State WI		Zip Code 54423		Subdivision Name				Lot #		Block #					
County		Co. Permit #		Notification #		Completed 11-01-2004		Latitude / Longitude in Decimal Degree (DD) 44.5064 °N -89.4319 °W				Method Code GCD013							
Well Constructor (Business Name) DONALD J FIRKUS SR				Lic. # 222		Facility ID # (Public Wells)		NW NE Section Township Range or Govt Lot # 5 23 N 9 E		2. Well Type Replacement									
Address FIRKUS WELL DRILLING AMHERST WI 54406-9189				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in											
Hicap Permanent Well #				Common Well #		Specific Capacity 10		Reason for replaced or reconstructed well ? Old well plugged up											
3. Well serves 1 # of				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled											
Private, potable				Hicap Potable ?															
Heat Exchange ___ # of drillholes																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		75		No Rotary - Mud Circulation		No		T S Y -		Tan/Brown, Soft/Loose, Sand & Gravel		Surface		30			
						No Rotary - Air		No		G H X -		Gray, Hard/Firm, Sand & Clay		30		50			
						No Rotary - Air & Foam		No		T S Y C		Tan/Brown, Soft/Loose, Sand & Gravel, Clayey		50		66			
						No Drill-Through Casing Hammer				T S Y -		Tan/Brown, Soft/Loose, Sand & Gravel		66		75			
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						Dual Rotary													
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		48 ft. below ground surface				18 in. above grade					
6		A53B 18.99 Paragon Weld				Surface		71		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 49 ft. below surface				Disinfected ? Yes					
6		12 slot Telescoping Stainless Steel				71		75		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?		Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Owner given form											
		Surface																	
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												DF						11-12-2004	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												LM						11-12-2004	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		86	Building Overhang		8
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 11-16-2004

Updated On: 05-07-2020

Review Status: APPROVED