Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SB485

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, TRACY			Phone #
Mailing Address: 7063 COON ROCK RD			
City: ARENA	State: WI	Zip Code: 53503	
County: Iowa	Co. Permit #	Notification #	Completed: 02-15-2005

Well Constructor (Business Name): SAM RODAMAKER	Lic. #: 349	Facility ID # (Public Wells)	
Address: WATERMAKER WELL DRLG&WATER SYS LLC SPRING GREEN WI 53588-8904		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

1. Well Location

Town of ARENA

Fire # (if avail.)

Street Address or Road Name and Number: PINE RD

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
NW SW or Govt Lot #	Section: 17	Township: 8 N	Range: 5 E

2. Well Type New Well — XI324 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2.5	WHITEWATER PITLESS	Surface	5
1.25	GALVANIZED SAWHILL	5	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON STAINLESS 10 SLOT	36	40

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	40

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at _____ GP for _____ Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
BR		03-01-2005
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		98	Downspout/Yard Hydrant		12
Building Drain - Sanitary		25	Landfill		1600
Building Overhang		12	Sewer - Building Sanitary		28
			Septic or Holding, or POWTS Tank		70

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	04/24/2014	NEAT CEMENT GROUT 0-40' 2 SACKS USED	NEW WELL

Created On: 03-29-2005 Updated On: 09-10-2015 Review Status: