

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SB485		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																							
Property Owner JOHNSON, TRACY					Phone #			1. Well Location				Fire # (if avail.)																					
Mailing Address 7063 COON ROCK RD					Town of ARENA							Street Address or Road Name and Number PINE RD																					
City ARENA			State WI		Zip Code 53503																												
County Iowa		Co. Permit #		Notification #			Completed 02-15-2005			Subdivision Name			Lot #		Block #																		
Well Constructor (Business Name) SAM RODAMAHER				Lic. # 349		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code																				
Address WATERMAKER WELL DRLG&WATER SYS LLC SPRING GREEN WI 53588-8904				Well Plan Approval #			NW SW Section Township Range or Govt Lot # 17 8 N 5 E		2. Well Type New Well XI324 replaces this well of previous unique well # constructed in																								
				Approval Date (mm-dd-yyyy)																													
Hicap Permanent Well #			Common Well #			Specific Capacity			Reason for replaced or reconstructed well ?																								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?																											
4. Potential Contamination Sources - ON REVERSE SIDE																																	
5. Drillhole Dimensions and Construction Method																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 40%; padding: 5px;"> Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia </td> <td style="width: 60%; padding: 5px;"> Lower Open Bedrock </td> </tr> </table>														Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia	Lower Open Bedrock																		
Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia	Lower Open Bedrock																																
8. Geology																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">Geology Codes</td> <td style="width: 45%;">Type, Caving/Noncaving, Color, Hardness, etc...</td> <td style="width: 15%;">From (ft.)</td> <td style="width: 25%;">To (ft.)</td> </tr> <tr> <td style="text-align: center;">- - S -</td> <td style="text-align: center;">SAND</td> <td style="text-align: center;">Surface</td> <td style="text-align: center;">40</td> </tr> </table>														Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	- - S -	SAND	Surface	40												
Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																														
- - S -	SAND	Surface	40																														
6. Casing, Liner, Screen																																	
Removed? ___ depth ft. (If NO explain on back side)																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width: 10%;">Dia. (in.)</th> <th style="width: 40%;">Material, Weight, Specification Manufacturer & Method of Assembly</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 35%;">To (ft.)</th> </tr> <tr> <td style="text-align: center;">2.5</td> <td>WHITEWATER PITLESS</td> <td style="text-align: center;">Surface</td> <td style="text-align: center;">5</td> </tr> <tr> <td style="text-align: center;">1.25</td> <td>GALVANIZED SAWHILL</td> <td style="text-align: center;">5</td> <td style="text-align: center;">36</td> </tr> <tr> <th style="width: 10%;">Dia. (in.)</th> <th style="width: 40%;">Screen type, material & slot size</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 35%;">To (ft.)</th> </tr> <tr> <td style="text-align: center;">1.25</td> <td>JOHNSON STAINLESS 10 SLOT</td> <td style="text-align: center;">36</td> <td style="text-align: center;">40</td> </tr> </table>														Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)	2.5	WHITEWATER PITLESS	Surface	5	1.25	GALVANIZED SAWHILL	5	36	Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)	1.25	JOHNSON STAINLESS 10 SLOT	36	40
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)																														
2.5	WHITEWATER PITLESS	Surface	5																														
1.25	GALVANIZED SAWHILL	5	36																														
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																														
1.25	JOHNSON STAINLESS 10 SLOT	36	40																														
9. Static Water Level																																	
20 ft. below ground surface																																	
10. Pump Test																																	
Pumping level ___ ft. below surface Pumping at ___ GP for ___ Hrs. Pumping Method ?																																	
11. Well Is																																	
14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																																	
7. Grout or Other Sealing Material																																	
Method																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width: 30%;">Kind of Sealing Material</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 15%;">To (ft.)</th> <th style="width: 40%;"># Sacks Cement</th> </tr> <tr> <td></td> <td style="text-align: center;">Surface</td> <td></td> <td></td> </tr> </table>														Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement		Surface														
Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement																														
	Surface																																
12. Notified Owner of need to fill & seal ?																																	
Filled & Sealed Well(s) as needed? NONE																																	
13. Constructor / Supervisory Driller																																	
BR										Lic #		Date Signed 03-01-2005																					
Drill Rig Operator										Lic or Reg #		Date Signed																					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		98	Downspout/Yard Hydrant		12
Building Drain - Sanitary		25	Landfill		1600
Building Overhang		12	Sewer - Building Sanitary		28
			Septic or Holding, or POWTS Tank		70

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	04/24/2014	NEAT CEMENT GROUT 0-40' 2 SACKS USED	NEW WELL

Created On: 03-29-2005

Updated On: 09-10-2015

Review Status: