

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SB979		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WALDMER, MARK						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address PO BOX 712						Town of PACKWAUKEE						N3291			
City PACKWAUKEE						State WI		Zip Code 53953				Street Address or Road Name and Number N3291 CO M			
County Marquette		Co. Permit #		Notification # 55093032		Completed 04-21-2015		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) TODD G ROOS				Lic. # 6287		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7614 °N -89.4728 °W				Method Code GCD013	
Address BOX 223 OXFORD WI 53952				Well Plan Approval #		NE SE		Section 19		Township 15 N		Range 9 E		2. Well Type Replacement	
Hicap Permanent Well #				Common Well #		Specific Capacity 5				of previous unique well # constructed in					
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No		MORE WATER									
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		160		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		16					
- - C S				SANDY CLAY				16		38					
- - C -				CLAY				38		113					
- S N -				SOFT SANDSTONE				113		134					
- H N -				FIRM SANDSTONE				134		160					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		6.625 OD X .280 WALL A53B PE 18.97 LBS IPSCO				Surface		134							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material		Method MOUNDED				Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement			
#8 BENTONITE		Surface				4 S		9. Static Water Level				11. Well Is			
5 ft. below ground surface						24 in. above grade									
10. Pump Test						Developed ? Yes									
Pumping level 8 ft. below surface						Disinfected ? Yes									
Pumping at 15 GP for 24 Hrs.						Capped ? Yes									
Pumping Method ?						12. Notified Owner of need to fill & seal ?									
Filled & Sealed Well(s) as needed?						Yes									
13. Constructor / Supervisory Driller						Lic #		Date Signed							
TOR						04-24-2015		Drill Rig Operator							
TOR						Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: VACANT LOT

Created On: 06-08-2015

Updated On: 04-08-2020

Review Status: