Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SB979

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALDMER, MARK	Phone #
Mailing Address: PO BOX 712	
City: PACKWAUKEE	State: WI — Zip Code: 53953

County	Co. Permit #	Notification #	Completed
Marquette		55093032	04-21-2015

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TODD G ROOS	6287	

Address: BOX 223, OXFORD WI 53952

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		5

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of PACKWAUKEE

Fire # (if avail.): N3291

Street Address or Road Name and Number: N3291 CO M

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.7614 °N	-89.4728 °W			GCD013

NE SE or Govt Lot #	Section	Township	Range
	19	15 N	9 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
MORE WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	160

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	16
-	-	C	S	SANDY CLAY	16	38
-	-	C	-	CLAY	38	113
-	S	N	-	SOFT SANDSTONE	113	134
-	H	N	-	FIRM SANDSTONE	134	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 OD X .280 WALL A53B PE 18.97 LBS IPSCO	Surface	134
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 8 ft. below surface
Pumping at 15 GP for 24 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		4 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TOR		04-24-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TOR		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: VACANT LOT

Created On: 06-08-2015 Updated On: 04-08-2020 Review Status: