

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SD224		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner INGLI, GERALD						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 407						Town of CRYSTAL LAKE							
City ELLSWORTH						State WI		Zip Code 54011-					
County Barron		Co. Permit #		Notification #		Completed 11-10-2004		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) CLARENCE BEECROFT				Lic. # 426		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address CLARENCE BEECROFT & SONS FREDERIC WI 54837-5707				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 19 35 N 14 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		110		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 6in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...			
								- - C - CLAY		Surface 40			
								- - P - HARD PAN		40 95			
								- - S - SAND		95 110			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		NEW BLACK STEEL 18.97 .280 WALL WELDED IPSCO				Surface		106		10 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
4		SS #18				106		110		15 in. above grade			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
BENTONITE GRANULES				Surface		20							
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
CB										11-10-2004			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		75	Shoreline/Pool		200
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 10-11-2005

Updated On: 10-11-2005

Review Status: