

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SE723		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DOROW, JASON						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address S3603 ABLEMAN RD						Town of EXCELSIOR				S3603			
City REEDSBURG						State WI		Zip Code 53959				Street Address or Road Name and Number S3603 ABLEMAN RD	
County Sauk		Co. Permit #		Notification #		Completed 11-05-2004		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) WILLIAM J SMITH				Lic. # 518		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.5133 °N -89.9204 °W				Method Code GCD013	
Address WM J SMITH WELL DRILLING BARABOO WI 53913				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 17 12 N 5 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 3									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.5 Surface 40.5													
6 40.5 98			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary No Cable-tool Bit ___ in. dia... Yes Dual Rotary Yes Temp. Outer Casing 9in. dia Yes Removed? 7depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
- - S -			SAND						Surface 7				
- - N -			SANDSTONE						7 98				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
6		STEEL ASTM A53 18.97 GRADE B WELDED JOINT MAVERICK USA				Surface 40.5							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
7. Grout or Other Sealing Material													
Method TREMIE PIPE PUMPED													
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement									
PORTLAND CEMENT		Surface 40.5		9 S									
9. Static Water Level													
25 ft. below ground surface													
10. Pump Test													
Pumping level 30 ft. below surface													
Pumping at 15 GP M for 4 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No NONE ON PROPERTY													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
WJS		11-05-2004											
Drill Rig Operator		Lic or Reg #		Date Signed									
WJS													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		106	Foundation Drain to Clearwater		30
Building Overhang		27	Sewer - Building Sanitary		43
			Septic or Holding, or POWTS Tank		81

Comment:

Created On: 03-29-2005

Updated On: 03-30-2020

Review Status: