

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SE726		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LEGNER, CRAIG						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address E5281 CO RD K						Town of REEDSBURG						E5281					
City REEDSBURG						State WI		Zip Code 53959				Street Address or Road Name and Number E5281 CO RD K					
County Sauk		Co. Permit #		Notification #		Completed 11-15-2004		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) WILLIAM J SMITH				Lic. # 518		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.5247 °N -90.0548 °W				Method Code GCD013			
Address WM J SMITH WELL DRILLING BARABOO WI 53913				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 18 12 N 4 E				2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL DOESNT MEET CODE							
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 3		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.) 8.5		From (ft.) Surface		To (ft.) 82.5		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes - - C G		Type, Caving/Noncaving, Color, Hardness, etc... CLAY & STONES		From (ft.) Surface		To (ft.) 14	
6		82.5		192		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 9in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		No		- - L - - - N -		LIMESTONE SANDSTONE		14 64 192		64	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly STEEL ASTM A53 18.97 GRADE B WELDED JOINT MAVERICK USA				From (ft.) Surface		To (ft.) 82.5		98 ft. below ground surface				18 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 103 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material Method TREMIE PIPE PUMPED						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? TO BE ABANDONED						No					
Kind of Sealing Material PORTLAND CEMENT		From (ft.) Surface		To (ft.) 82.5		# Sacks Cement 15 S		13. Constructor / Supervisory Driller WJS				Lic #		Date Signed 11-15-2004			
						Drill Rig Operator WJS				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Downspout/Yard Hydrant		43
Building Overhang		19	Sewer - Building Sanitary		64
Clearwater Sump		45	Septic or Holding, or POWTS Tank		66

Comment:

Created On: 01-11-2005

Updated On: 03-30-2020

Review Status: