Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SH617

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRUESER, DENNIS			Phone #
Mailing Address: N4953 OAKVIEW DR			
City: WEST SALEM	State: WI	Zip Code: 54669	
County: La Crosse	Co. Permit #: 24440	Notification #	Completed: 09-22-2004

Well Constructor (Business Name): SYLVESTER R HAUPT	Lic. #: 489	Facility ID # (Public Wells)	
Address: HAUPT WELL DRLG AUBURNDALE WI 54412		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of HAMILTON				Fire # (if avail.): N4953
Street Address or Road Name and Number				
Subdivision Name: BRAIRCLIFF ADD			Lot #: 22	Block #
Latitude / Longitude in Decimal Degree (DD): 43.9 °N -91.1361 °W				Method Code: GCD013
SE SE or Govt Lot #	Section: 31	Township: 17 N	Range: 6 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	4
8	4	124
6	124	155

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	1
-	-	C	-	CLAY	1	11
-	-	N	-	SANDSTONE	11	147
U	-	H	-	BLUE SHALE	147	155

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B 280 WALL WELDED US SAWHILL	Surface	127
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PACKER PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	127	18 S

9. Static Water Level
93 ft. below ground surface

10. Pump Test
Pumping level 121 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
30 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
SH		09-27-2004
Drill Rig Operator	Lic or Reg #	Date Signed
TP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120

Type	Qualifier	Distance
Building Overhang		19
Septic or Holding, or POWTS Tank		90

Comment:

Created On: 11-03-2004 Updated On: 04-30-2020 Review Status: