

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SJ797		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ABBOTT, DOYLE					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 21221 WASHINGTON AVE							Town of YORKVILLE						
City KANSASVILLE					State WI		Zip Code 53139						
County Racine		Co. Permit #		Notification #		Completed 10-12-2004		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) HOOVER WELL DRILLING CO INC				Lic. # 6448		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.7456 °N -88.0709 °W				Method Code GCD013	
Address 4701 HAAG DR UNION GROVE WI 53182				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 6 3 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
9		Surface		9									
5		9		165		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		No No					
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
U - C -		BLUE CLAY		Surface		50							
- - P -		HARDPAN		50		70							
U - C -		BLUE CLAY		70		130							
- - P -		HARDPAN		130		162							
- - G -		GRAVEL		162		165							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)							
5		SAWHILL STEEL T&C 15.00 PPF A53B ASTM		Surface		165							
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)							
7. Grout or Other Sealing Material													
Method STARTER HOLE													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE		Surface											
9. Static Water Level													
100 ft. below ground surface													
10. Pump Test													
Pumping level 120 ft. below surface													
Pumping at 10 GP M for 6 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NON-OBSERVED													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
WM		10-13-2004											
Drill Rig Operator		Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Comment: WELL WAS ABANDONED

Abandonment Type	Abandonment Date	Procedure	Reason

Created On: 11-09-2004

Updated On: 06-27-2019

Review Status: