

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SJ798		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner VERWEY, JIM					Phone #		1. Well Location				Fire # (if avail.)								
Mailing Address 1292 VILLAGE CENTER					Town of YORKVILLE					Street Address or Road Name and Number 5104 CRYSTAL LN									
City STURTEVANT			State WI		Zip Code 53177														
County Racine		Co. Permit #		Notification #		Completed 10-08-2004		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) HOOVER WELL DRILLING CO INC				Lic. # 6448		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address 4701 HAAG DR UNION GROVE WI 53182				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 35 3 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #			Common Well #		Specific Capacity 2														
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		9		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		U - C - BLUE CLAY - - G - GRAVEL		Surface 141 141 150		Yes No							
5		9		150															
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		130 ft. below ground surface				12 in. above grade					
5		SAWHILL STEEL T&C 15.00 PPF A53B ASTM				Surface		147		10. Pump Test Pumping level 140 ft. below surface Pumping at 20 GP M for 6 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
5		TELESCOPIC SS 15 SLOT				147		150											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NON-OBSERVED							
Method STARTER HOLE																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE				Surface															
(Empty space for additional information)												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												WM				10-19-2004			
												Drill Rig Operator				Lic or Reg #		Date Signed	
												(Empty space for additional information)				(Empty space for additional information)		(Empty space for additional information)	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Foundation Drain to Clearwater		20	Sewer - Building Sanitary		25
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 11-16-2004

Updated On: 11-16-2004

Review Status: