

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SN360		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WEISENBECK, VICKI						Phone # (715)495-4818		1. Well Location				Fire # (if avail.)							
Mailing Address 253 MONROE ST						Town of DRAMMEN						Street Address or Road Name and Number S14940 HOYTS CREEK RD							
City MONDOVI				State WI		Zip Code 54755													
County Eau Claire		Co. Permit # 31024		Notification # 41129358		Completed 08-22-2011		Subdivision Name				Lot # 2		Block #					
Well Constructor (Business Name) JAMES A WILCOX				Lic. # 6028		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.6122 °N -91.6037 °W				Method Code GCD013					
Address WATER WELL SPECIALISTS ALTOONA WI 54720				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 28 25 N 10 W		2. Well Type Replacement of previous unique well # AP577 constructed in Reason for replaced or reconstructed well ? 4IN STEEL PIPE SET IN OLD CHINA CASING											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.4		Construction Type Drilled													
3. Well serves 1 # of Private, potable				Hicap Well ? No															
Heat Exchange ___ # of drillholes				Hicap Property ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		36		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing 10in. dia Removed? 14depth ft. (If NO explain on back side)		- - I - TOP SOIL T - S - BRN SAND T H N - HARD BRN SANDSTONE E H N - HARD GREEN SANDSTONE		Surface		2							
6		36		63						2		7							
7		36		63						7		14							
8		36		63						14		63							
9		36		63						14		63							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface				18 in. above grade					
6		EXL TUBE ASTM/A53/ASME .280IN WELL PLAIN END PIPE, WELDED				Surface		38		Pumping level 30 ft. below surface				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 48 Hrs.				Disinfected ? Yes					
6		1/2" x 1/8"				10		38		Pumping Method ?				Capped ? Yes					
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method TREMIE PIPE-PUMPED BOTTOM UP												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT GROUT				Surface		38		14 S											
(Empty space for additional information)												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JAW				08-22-2011			
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		74	Building Overhang		10
Building Drain - Sanitary		36	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 09-20-2011

Updated On: 08-01-2019

Review Status: