Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SN360

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEISENBECK, VICKI	Phone #: (715)495-4818
Mailing Address: 253 MONROE ST	
City: MONDOVI	State: WI Zip Code: 54755

County	Co. Permit #	Notification #	Completed
Eau Claire	31024	41129358	08-22-2011

Well Constructor (Business Name): JAMES A WILCOX	Lic. #: 6028
Address: WATER WELL SPECIALISTS ALTOONA WI 54720	
Facility ID # (Public Wells)	
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	

Hicap Permanent Well #	Common Well #	Specific Capacity: 1.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of DRAMMEN

Fire # (if avail.)

Street Address or Road Name and Number: S14940 HOYTS CREEK RD

Subdivision Name	Lot #	Block #
	2	

Latitude / Longitude in Decimal Degree (DD): 44.6122 °N -91.6037 °W
Method Code: GCD013

SW	SW	Section	Township	Range
or Govt Lot #		28	25 N	10 W

2. Well Type Replacement
of previous unique well # AP577 constructed in

Reason for replaced or reconstructed well ?
4IN STEEL PIPE SET IN OLD CHINA CASING

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	36
6	36	63

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia... No
Dual Rotary .....
Temp. Outer Casing 10in. dia
Yes Removed? 14depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	2
T	-	S	-	BRN SAND	2	7
T	H	N	-	HARD BRN SANDSTONE	7	14
E	H	N	-	HARD GREEN SANDSTONE	14	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	EXL TUBE ASTM/A53/ASME .280IN WELL PLAIN END PIPE, WELDED	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method TREMIE PIPE-PUMPED BOTTOM UP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	38	14 S

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 48 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAW		08-22-2011
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		74	Building Overhang		10
Building Drain - Sanitary		36	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 09-20-2011 Updated On: 08-01-2019 Review Status: