Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: SN363

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOMPKINS, DEAN	Phone #
Mailing Address: 518 THAYER	
City: KENDALL	State: WI — Zip Code: 54638

County	Co. Permit #	Notification #	Completed
Chippewa	30711	40107906	08-25-2011

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JAMES A WILCOX	6028	

Address: WATER WELL SPECIALISTS, ALTOONA WI 54720

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.2

3. Well serves # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

1. Well Location

Town of LAFAYETTE

Fire # (if avail.)

Street Address or Road Name and Number: 8208 183RD ST

Subdivision Name	Lot #	Block #
PINE HARBOR 1ST	13	

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.9624	°N	-91.3017	°W	GCD013

SE	SW	Section	Township	Range
or Govt Lot #		25	29 N	8 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40.5

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	Y	-	BRN SAND/GRAVEL	Surface	16.5
T	-	Y	G	BRN SAND/GRAVEL/COBBLES	16.5	22.5
G	J	S	-	SAND W/ORANGE IRON COLOR	22.5	35
T	-	Y	-	BRN SAND/GRAVEL	35	40.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A53 .280IN P/E EXL TUBE WELDED	Surface	37.75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. TELESCOPIC .025IN JOHNSON	36.5	40.5

7. Grout or Other Sealing Material

Method MOUNDED IN STARTER

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANULAR	Surface		

9. Static Water Level

2.3 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 15 GP M for 192 Hrs.

Pumping Method ?

11. Well Is

42 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

(NONE)

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		08-25-2011
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		70	Shoreline/Pool		60
Building Overhang		20	Privy		99
			Septic or Holding, or POWTS Tank		93

Comment: PRIVY TO BE REMOVED

Created On: 09-20-2011 Updated On: 06-11-2020 Review Status: