Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SN840

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LAVOY, SIDEY	Phone #
Mailing Address: PO BOX 293	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #	Notification #	Completed: 12-01-2004
Well Constructor (Business Name): GARY A OLSON	Lic. #: 5831	Facility ID # (Public Wells)
Address: GARY OLSON WELL DRILLING, SPRINGBROOK WI 54875-9743	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.6

1. Well Location

Town of SAND LAKE				Fire # (if avail.): 6670N
Street Address or Road Name and Number: OLD 27 RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 45.8766 °N -91.499 °W				Method Code: GCD013
NW / SW or Govt Lot #:	Section: 9	Township: 39 N	Range: 9 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of CAMPER
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	61

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	M	S	SILT SAND	Surface	50
-	-	Y	M	SILT SAND GRAVEL	50	58
-	-	Y	-	SAND GRAVEL	58	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ISPOIC A53-B PE WELDED	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	10 SLOT SS	57	61

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
45 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 8 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
GO		12-01-2004
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
Building Overhang		20

Comment:

Created On: 01-11-2005 Updated On: 06-24-2020 Review Status: