

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SN840		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LAVOY, SIDEY					Phone #			1. Well Location Fire # (if avail.) Town of SAND LAKE 6670N Street Address or Road Name and Number OLD 27 RD					
Mailing Address PO BOX 293													
City HAYWARD			State WI		Zip Code 54843		Subdivision Name Lot # Block #						
County Sawyer		Co. Permit #		Notification #		Completed 12-01-2004							
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
GARY A OLSON				5831				45.8766 °N -91.499 °W				GCD013	
Address GARY OLSON WELL DRILLING SPRINGBROOK WI 54875-9743				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SW		Section Township		Range	
								or Govt Lot #		9 39 N		9 W	
Hicap Permanent Well #			Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
					1.6								
3. Well serves 1 # of CAMPER Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
4		Surface		61									
						Rotary - Mud Circulation							
						Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit 4in. dia...			No				
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
- - M S				SILT SAND				Surface		50			
- - Y M				SILT SAND GRAVEL				50		58			
- - Y -				SAND GRAVEL				58		61			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
4		ISPOIC A53-B PE WELDED				Surface		57					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
3		10 SLOT SS				57		61					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
				Surface									
9. Static Water Level 45 ft. below ground surface													
10. Pump Test Pumping level 50 ft. below surface Pumping at 8 GP M for 2 Hrs. Pumping Method ?													
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
GO								12-01-2004					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance
Building Overhang		20

Comment:

Created On: 01-11-2005

Updated On: 06-24-2020

Review Status: