Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SR421

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GOLLA, JOE	Phone #: (715)592-6340
Mailing Address: 4395 CO RD J NORTH	
City: CUSTER	State: WI — Zip Code: 54423
County: Portage	Co. Permit #:
Notification #: 20644557	Completed: 08-30-2005
Well Constructor (Business Name): ALPHA DRILLING SERVICES INC	Lic. #: 6182
Facility ID # (Public Wells):	
Address: 8658 RILEY RD AMHERST WI 54406	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4.5	

1. Well Location

Town of SHARON

Fire # (if avail.):

Street Address or Road Name and Number: 4395 CO RD J NORTH

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.6678 °N -89.424 °W

Method Code: GCD013

NW	NW	Section	Township	Range
or Govt Lot #		9	25 N	9 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NO WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	54.5

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLACK DIRK	Surface	0.5
-	-	Y	G	SAND & GRAVEL, BOULDERS	0.5	19
-	-	Y	-	SAND & GRAVEL	19	54.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 X .280 PE WELDED JOINT A-53 IPSCO	Surface	51.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	STAINLESS 12 SLOT	51.5	54.5

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MOUNDED	Surface		2 S

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EG		08-30-2005
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70

Type	Qualifier	Distance
Building Overhang		15
Septic or Holding, or POWTS Tank		57

Comment:

Created On: 09-26-2005 Updated On: 05-07-2020 Review Status: